

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# Wilsonart LLC

2501 Wilsonart Drive, Temple, TX, United States

For the following product(s):

## High Pressure Decorative Laminates:

Compact Panel, Fire-Rated Panel, Series: 107, 335, 350, 376, 735

*Excludes non-U.S.A. manufactured or assembled HPDL*

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## Indoor Advantage™ Gold

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the ANSI/BIFMA Furniture Emissions Standard (M7.1/X7.1-2011 R2016) and ANSI/BIFMA e.3 -2019 (Credits 7.6.1, 7.6.2, 7.6.3) for the open plan and private office workstation parameters<sup>1,2</sup>. Also conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 (effective January, 2017) for the open plan<sup>1</sup>, private office<sup>2</sup>, school classroom<sup>2</sup> parameters.

<sup>1</sup> Modeled Product Type: Individual Furniture Components

<sup>2</sup> Modeled Product Type: Flooring

Measured Concentration of Total Volatile Organic Compounds (TVOC)<sup>2</sup>: Less than/equal to 0.5 mg/m<sup>3</sup>

Registration # SCS-IAQ-02654

Valid from: October 1, 2019 to September 30, 2020



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA