

LGA - Qualitäts - Zertifikat

LGA-Quality-Certificate

Genehmigungsinhaber
License Holder

Hawa AG
Untere Fischbachstr. 4
8932 Mettmenstetten
Schweiz

Zertifiziertes Produkt (umseitig näher bezeichnet)
Certified Product (specified overleaf)

Sliding door fitting
HAWA-Junior 80/B (mod.)
Art.No. 24617 and 24851

Prüfzeichen *Test Mark*



LGA-Qualitäts-Zertifikats-Nr.: LI 60106912 0001
LGA-Quality-Certificate No.

Untersuchungsbericht-Nr.: 21244670 001
Test Report No.

Geprüft nach *Tested acc. to*
DIN EN 1527/03.13
DIN EN 15706/08.09
2 PfG Q2274/05.13

Datum *Date* 03.02.2016
Zertifizierungsstelle *Certification Body*

17.11.16
Andre Henning


Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
This certificate is based on our Testing and Certification Regulations.
Das Produkt entspricht o.g. Anforderungen, die Herstellung wird überwacht.
The product fulfills above mentioned requirements, the production is subject to surveillance.

Übersetzung/Translation

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg
Tel.: +49 221 806-1371 Fax: +49 221 806-3935 e-mail: cert-validity@de.tuv.com <http://www.tuv.com/safety>

Genehmigungsinhaber License Holder

Hawa AG
Untere Fischbachstr. 4
8932 Mettmenstetten
Schweiz

Fertigungsstätte Manufacturing Plant

Hawa AG
Untere Fischbachstr. 4
8932 Mettmenstetten
Schweiz

Ihr Zeichen Client Reference	Unser Zeichen Our Reference	Längstens gültig bis Latest expiration date (day/mo/yr)
-------------------------------------	------------------------------------	---

0010--21244670 001

Zertifiziertes Produkt (Geräteidentifikation) <i>Certified Product (Product Identification)</i>	Lizenzentgelte - Einheit <i>License Fee - Unit</i>
---	--

Fittings

Sliding door fitting
HAWA-Junior 80/B (mod.)
Art.No. 24617 and 24851

6

Strength, functionality, requirements acc. to 2 PFG-Q 2274
Technical safety DIN EN 15706 level 3 and
properties DIN EN 1257 fulfilled

Operating forces < 15N

Classification acc. to see appendix
DIN EN 1527

Loading capacity 80 kg

durability 100.000 cycles

Quality assurance third party monitoring and self-
monitoring

6

Anlage / Appendix 1



Zertifikat / Certificate

Blatt / Page

LI 60106912

0001

Ihr Zeichen / Client Reference

Unser Zeichen / Our Reference

Ausstellungsdatum / Date of issue

0010-- 21244670_001

03.02.2016

Classification acc. to DIN EN 1527

-	6	2	-	1	0	-	1	3
---	---	---	---	---	---	---	---	---

Category of use (1st digit):

No grade identified for these products.

Durability (2nd digit):

- grade 1 = 5000 test cycles
- grade 2 = 10000 test cycles
- grade 3 = 25000 test cycles
- grade 4 = 50000 test cycles
- grade 5 = 75000 test cycles
- grade 6 = 100000 test cycles

Door mass (3rd digit):

- grade 1 = door up to 50 kg
- grade 2 = door from 51 kg to 100 kg
- grade 3 = door from 101 kg to 330 kg
- grade 4 = door over 330 kg

Fire resistance (4th digit):

No grade identified for these products.

Safety (5th digit):

All sliding design systems and sliding folding design systems conforming to this standard shall be classified as grade 1 for safety.

Corrosion resistance (6th digit):

Products are classified from 1 to 5 according to the six grades defined in EN 1670.
Grade 0 is for products not tested.

Security (7th digit):

No grade identified for these products.

Category of door (8th digit):

- grade 1 = sliding door
- grade 2 = folding door (bi-fold type)
- grade 3 = multi-panel folding door

Initial friction maximum permitted value (9th digit):

Door mass	from 0 kg to 50 kg	from 51 kg to 100 kg	from 101 kg to 330 kg	Over 330 kg
Grade 1	50 N	80 N	100 N	5 % of the mass
Grade 2	40 N	60 N	5 % of the mass	4 % of the mass
Grade 3	30 N	40 N	4 % of the mass	3 % of the mass



Übersetzung/Translation